

# Hygrothermal Evaluation of a Museum Storage Building Based on Actual Measurement and Simulations



Jørgen Erik Christensen & Christos Georgios Kollias  
Department of Civil Engineering  
Technical University of Denmark, Denmark


# Presentation overview



1. Theoretical background
2. Description of building
3. Scopes of analysis
4. Methodology
5. Building modelling
6. Results analysis
7. Conclusion




# Description of the examined building



Vejle museum storage building

- Shared storage facility
- The storage facilities are consisted of an old (2005) and a new part (2012)
- Apart from the storage space, Vejle museum storage includes a conservation center, offices and working areas for the staff
- Supporting facilities (e.g. packing room, cold store, freeze disinfection compartment)

# Description of the examined building



Floor plan of the **OLD (left)** and the **NEW (right)** part of Veje museum storage facilities

- Airtightness
  - 0.04 ACH old part
  - 0.01 ACH new part
- No windows
- Thick walls
- Uninsulated floor
- No heating/cooling systems
- Conc. Dehumidification
  - 00:00 – 06:00 old part
  - 00:00 – 03:00 new part
- Sufficient insulation

## ➤ Indoor climate

- RH 50% ( $\pm 5\%$ ), T: 7 to 18 ° C (Desired T: 12 to 14° C)

# Scopes of the analysis



- Illustrate how model for a large Museum magazine can be set up and analyzed
- Compare simulation model with measurements
- Investigate building's behavior in terms of temperature levels

# Methodology



General building modelling with **IDA ICE** & **BSim** software using **actual weather data**



Evaluate the indoor climate in terms of temperature levels (predicted vs measured temperatures)

**Problem** : IDA ICE and BSim allow **1D** approach, while thermal interaction between building indoor environment and the soil below is a **3D** interaction

Modelling of the foundations with the **HEAT2** software




Study the heat exchange through the ground

# Building modeling

➤ Develop a **HEAT2 model** for the investigation of the heat exchange through the ground

- **3D** → **2D** → UNI EN ISO 13370:  $B' = \frac{A}{\frac{1}{2}P}$



- Using the **HEAT2** software the heat flow through the ground is calculated for the 2D model
- The simulation time interval is 10 years
- Only results of the last year of simulations will be used

# Building modeling

## ➤ 2D → 1D

- The calculated heat flow from the 2D model is used to specify the soil thickness of the 1D model

$$q_{\text{floor 2D}} = q_{\text{floor 1D}}$$

$$q_{\text{floor}} = U_{\text{floor}} \times \Delta T \Rightarrow U_{\text{floor}} = \frac{q_{\text{floor}}}{\Delta T}$$


$$U_{\text{floor}} = \frac{1}{R_{si} + \frac{d_{\text{concrete}}}{\lambda_{\text{concrete}}} + \frac{d_{\text{LECA}}}{\lambda_{\text{LECA}}} + \frac{d_{\text{soil}}}{\lambda_{\text{soil}}} + R_{se}} \quad \left[ \frac{W}{m^2 K} \right]$$



- Soil thickness should be precisely calculated in order to provide the same heat flow as the 2D model




# Building modeling



- Equal average heat flow
- **Amplitude** difference (>10%)
- **Phase shift**


- Area close to the foundation is more vulnerable to outdoor weather conditions
- Less time to reach equilibrium with outdoor conditions



# Building modeling

➤ Solution based on the UNI EN ISO 13370 suggestion:


*The ground has to be subdivided in such way that the subdivisions are smaller near the edge of the floor and gradually increasing in size to much larger near the truncation planes*



# Building modeling



## Agreement 2D – 1D model (divided floor)




- **Amplitude** difference is improved:
  - 8.4% for 5 parts
  - 7.5% for 7 parts
- **Phase shift** is corrected:
  - Slight difference between 2D and 1D models (divided floor)


- Develop two different HEAT2 models for each building part
  - $B'$  is calculated for the entire floor area independent from construction and material composition
  - Heat losses are distributed proportional to the fraction of the outside perimeter of the two zones

# Building modeling

- IDA ICE & BSim model **before** the expansion (only the old storage 2006 – 2011)
- IDA ICE & BSim model **after** the expansion (old and new storage 2012 – 2013)




- Simulate the model with a 10 year dynamic start up phase in order the indoor climate to be stabilized



# Results analysis




## Predicted & measured temperature in the **OLD STORAGE** during 2006



# Results analysis




## Predicted & measured temperature in the **OLD STORAGE** during 2010



# Results analysis




**BSim results for the OLD STORAGE before and after the use of several weather files in a single simulation process for 2010**



# Results analysis



Predicted & measured temperature in the **NEW STORAGE** during 2012 - 2013






# Results analysis




## Temperature within the OLD STORAGE before and after the expansion (**IDA ICE** & **Bsim** results)



# Results analysis



## Hourly values for indoor and outdoor air temperature



# Results analysis



## Required dehumidification load to maintain RH at 50%

Dehumidification load = Infiltration + People moisture - Exfiltration

| Month                              | Infiltration [kg/month] |             | Exfiltration [kg/month] |             | People Moisture [kg/month] |              | Dehumidification [kg/month] |             |
|------------------------------------|-------------------------|-------------|-------------------------|-------------|----------------------------|--------------|-----------------------------|-------------|
|                                    | OLD                     | NEW         | OLD                     | NEW         | OLD                        | NEW          | OLD                         | NEW         |
| January                            | 2658                    | 468         | 2317                    | 482         | 1.38                       | 5.52         | 342                         | -9          |
| February                           | 2417                    | 425         | 2064                    | 425         | 1.20                       | 4.80         | 353                         | 5           |
| March                              | 2417                    | 425         | 2255                    | 463         | 1.26                       | 5.04         | 163                         | -32         |
| April                              | 3332                    | 587         | 2579                    | 477         | 1.32                       | 5.28         | 754                         | 115         |
| May                                | 4429                    | 780         | 3099                    | 535         | 1.38                       | 5.52         | 1330                        | 250         |
| June                               | 5492                    | 967         | 3211                    | 543         | 1.20                       | 4.80         | 2283                        | 428         |
| July                               | 6686                    | 1177        | 3765                    | 608         | 1.38                       | 5.52         | 2923                        | 574         |
| August                             | 6415                    | 1129        | 3841                    | 629         | 1.32                       | 5.28         | 2576                        | 505         |
| September                          | 5446                    | 959         | 3489                    | 602         | 1.26                       | 5.04         | 1958                        | 362         |
| October                            | 4785                    | 842         | 3199                    | 591         | 1.38                       | 5.52         | 1588                        | 257         |
| November                           | 3214                    | 566         | 2642                    | 528         | 1.26                       | 5.04         | 573                         | 43          |
| December                           | 2827                    | 498         | 2388                    | 501         | 1.32                       | 5.28         | 440                         | 2           |
| <b>Sum [kg/year]</b>               | <b>50118</b>            | <b>8822</b> | <b>34851</b>            | <b>6385</b> | <b>15.66</b>               | <b>62.64</b> | <b>15283</b>                | <b>2500</b> |
| <b>Sum [kg/year/m<sup>2</sup>]</b> | <b>15.7</b>             | <b>4.3</b>  | <b>10.9</b>             | <b>3.1</b>  | <b>-</b>                   | <b>-</b>     | <b>4.8</b>                  | <b>1.2</b>  |

# Conclusions



- Good agreement between simulation and measurements
- Weather conditions of the previous years affect the indoor environment of the following years
- The expansion of Vejle museum storage with the new section benefits the indoor climate of the old building part
- The increased airtightness of the new part results in lower need for dehumidification as well as it minimizes the detrimental effect of paint on walls' moisture buffer contribution



Thank you!