



CommONEnergy

BuildSim nordic, Espoo, 25.-26.09.2014

# Capacities in Shopping centres to supply grid services

Matthias Haase, Ruth Woods and Kristian Skeie  
SINTEF Building and Infrastructure  
25/09/2014





CommONEnergy

## Content

- Background
- Purpose
- Theoretical framework
- Results and conclusions
- Implications for 'Resilience the New Research Frontier'



CommONEnergy

## Background

The CommONEnergy project wants to transform shopping malls into lighthouses of energy efficient architectures and systems.

The objective is to re-conceptualize shopping malls through deep retrofitting utilizing an holistic systemic approach involving innovative technologies and solution sets.

Performance targets:

- Up to 75% reduction of energy demand (factor 4)
- Power peak shaving
- 50% increased share of renewable energy source favoured by intelligent energy management and effective storage
- Improvement of comfort and health conditions for occupants and visitors





CommONEnergy

Capacities in Shopping centres to supply grid services

## Partners

- Monitoring and control system manufacturer
- HVAC, Refrigeration and Lighting manufacturer
- Storage systems manufacturers
- Solar system manufacturer
- Materials manufacturer
- Building enterprises
- R&D experts (building physics, HVAC+R systems, monitoring, lighting, materials)
- Engineering/Architectural consultants
- Building owners






CommONEnergy

Capacities in Shopping centres to supply grid services

## Purpose

Identification of potential in shopping malls to supply grid services, reducing the impact on power demand through

- peak shaving of its demand curve or its adaptation to the conditions of generation of the utilities, based on the classification of the demand.
- use of generation coming from renewable energy sources in moments of mismatch between energy supply and demand, either directly or from storage.



**Non-residential building stock (m<sup>2</sup>)**






CommONEnergy

Capacities in Shopping centres to supply grid services

## Energy use





CommONEnergy


## Energy use

Capacities in Shopping centres to supply grid services

Hypermarkets (Food-driven)



Nonfood retail formats







CommONEnergy


## Demo case

Capacities in Shopping centres to supply grid services







## Baseline plans Ground floor



## First floor



## Baseline zoning with grid






# Baseline Constructions

Building codes	TEK-1985	TEK-1987	TEK-1997	TEK-10
<b>Description</b>	<i>Building codes' as built to std. 1985'</i>	<i>Building codes year of completion</i>	<i>Redevelopment in 2000 (extension)</i>	<i>Current min. std. (for reference)</i>
U-value ext. wall (W/(m <sup>2</sup> K))	0,45*	0,30	0,22	0,18
U-value roof (W/(m <sup>2</sup> K))	0,23	0,23	0,15	0,13
U-value floor (W/(m <sup>2</sup> K))	0,30	0,30	0,15	0,15
U-value windows / doors (W/(m <sup>2</sup> K))	*to be included in the facade.	2,40	1,6 - 2,0	1,2
U-value doors / ports (W/(m <sup>2</sup> K))	2,0	2,0	2,0	1,2
air tightness c (ach)			1,50	
heat recovery d (%)				80 %
specific fan power (kW/(m <sup>3</sup> /s))				2,0/1,0

# Measured data 2012



## Avg. electricity profile




Increased electricity use

# Measured data 2012

## Avg. district heating profile



Mainly space heating




Domestic hot water



CommONEnergy

Capacities in Shopping centres to supply grid services

## Validated model









CommONEnergy

Capacities in Shopping centres to supply grid services

## Results

### Winter Week, 14. - 20. Jan | Shared electricity demand







CommONEnergy

Capacities in Shopping centres to supply grid services

## Results

Spring Week, 8. - 14. April | Shared electricity demand







CommONEnergy

Capacities in Shopping centres to supply grid services

## Results

Spring Week, 8. - 14. April | Reduced shared electricity demand






CommONEnergy

Capacities in Shopping centres to supply grid services

## PV system



- Trondheim: 63° 25' N, 10° 23' E (south of Arctic circle)
- Average solar resource: 2.38 kWh m<sup>-2</sup> d<sup>-1</sup> onto a flat plate, 3.03 kWh m<sup>-2</sup> d<sup>-1</sup> onto a PV panel tilted 45° to the south.
- Here: 500kW (3200m<sup>2</sup>), 1MW, almost horizontal installation



CommONEnergy

## Concepts/scenarios for decrease mismatch

		Indicator category	
		Load matching	Grid interaction
<b>Data requirements</b>	On-site load and generation	I Load match index <sup>1</sup> Solar fraction <sup>2</sup> Cover factor <sup>4</sup> Self-consumption factor <sup>7</sup> Loss of load probability <sup>4</sup>	II Grid interaction index <sup>1</sup> Capacity factor <sup>4</sup> Peak power indicators <sup>4</sup> Grid citizenship tool <sup>8</sup>
	Additional data	III Mismatch compensation factor <sup>5</sup> Market matching <sup>3</sup>	IV Profile addition indicators <sup>5</sup> Coincidence factor <sup>6</sup>

<sup>1</sup>Voss et al (2010), <sup>2</sup>Widén et al (2009), <sup>3</sup>Widén and Wäckelgard (2010), <sup>4</sup>Verbruggen et al (2001), <sup>5</sup>Lund et al (2011), <sup>6</sup> Willis and Scott (2000), <sup>7</sup> Castillo-Cagical et al (2010), <sup>8</sup> Colson and Nehrir (2009)





CommONEnergy

## Concepts/scenarios for decrease mismatch

- Load Cover Factor 
$$Y_{load} = \frac{\int_{\tau_1}^{\tau_2} \min[g(t) - S(t) - \zeta(t), l(t)] dt}{\int_{\tau_1}^{\tau_2} l(t) dt}$$
- Supply Cover Factor 
$$Y_{supply} = \frac{\int_{\tau_1}^{\tau_2} \min[g(t) - S(t) - \zeta(t), l(t)] dt}{\int_{\tau_1}^{\tau_2} g(t) dt}$$
- Grid interaction 
$$GI = \frac{g(t)}{l(t)}$$






CommONEnergy

Capacities in Shopping centres to supply grid services

## Results



- 500kW PV system






CommONEnergy

Capacities in Shopping centres to supply grid services

## Results



- 1 MW PV system






CommONEnergy

Capacities in Shopping centres to supply grid services

## Results

Spring Week, 8. - 14. April | grid interaction reduced lighting loads






CommONEnergy

Capacities in Shopping centres to supply grid services

## Results






CommONEnergy

Capacities in Shopping centres to supply grid services

## Results






CommONEnergy

Capacities in Shopping centres to supply grid services

## Results








CommONEnergy

Capacities in Shopping centres to supply grid services

## Results – including tenants





CommONEnergy

Capacities in Shopping centres to supply grid services

## Conclusions

- The results show that there is considerable potential for the use of generation coming from renewable energy sources.
- Peak shaving of power demand is possible but limited. It seems that PV production will exceed the energy needs only if they are strongly reduced.
- Grid interaction increases which gives options for energy storage (batteries).
  
- When tenants energy use is included, more work is needed in order to optimize the design of the building and the technical systems.
- Other RE sources should be considered (Wind power?).

Capacities in Shopping centres to supply grid services



CommONEnergy

**THANK YOU!**

